



شهادة مطابقة CERTIFICATE OF CONFORMITY

Certificate Number:	24-03-106290/E24-03-110155/NB0007	رقم الشهادة:
Registration Date:	29/03/2024	تاريخ التسجيل:
Valid Until:	28/03/2027	صالحة لغاية:
Issued To:	CMP Products Limited P.O. Box NE23 1WH ,36 Nelson Way, Nelson Park East Cramlington ,United Kingdom	أصدرت إلى :
Sector:	Electrical	قطاع: كهرباء
Product Category:	ECAS-Ex	تصنيف المنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار
Product Sub-Category:	ECAS-Ex	التصنيف الفرعي للمنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Please check Schedule of certification for all product details يرجى التحقق من بيان التسجيل المرفق لجميع تفاصيل المنتجات

intertek

Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



Products are registered under the Emirates Conformity Assessment Scheme (ECAS) based on compliance to the Approved Standards



المنتجات مسجلة في نظام تقويم المطابقة الإماراتي (إيكاس) بناء على مطابقتها للمواصفات المعتمدة

This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

Company Name:	CMP Products Limited	اسم الشركة:
Product Category:	ECAS-Ex	الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار تصنيف المنتج:
Certificate No.:	24-03-106290/E24-03-110155/NB0007	رقم التسجيل:
Registration Date:	29/03/2024	تاريخ التسجيل:
Valid Until:	28/03/2027	صالح لغاية:

Sr.No.	الاسم التجاري Brand Name	رقم الموديل Model Number	تفاصيل المنتج Product Details	تصنيف النجوم Star Rating	الأبعاد/الحجم Dimension/Size	التقارير Reports	المواصفات المطبقة Applicable Standards	بلد المنشأ Country Of Origin
--------	-----------------------------	-----------------------------	----------------------------------	-----------------------------	---------------------------------	---------------------	---	---------------------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

1	CMP	717	Stopping Plug; Type of Protection: Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da; Ts= -60°C to +95°C; IP66, IP67, IP68*, IP69, IP69K; *With sealing washer (30m for 16 hours) / Without sealing washer (1.1m for 5 days)	N/A	N/A	IECEX CML 20.0038X GB/CML/ExTR20.0044/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	---	-----	-----	---	--	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

2	CMP	717E	Stopping Plug; Type of Protection: Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da; Ts= -60°C to +95°C; IP66, IP67, IP68*, IP69, IP69K; *With sealing washer (30m for 16 hours) / Without sealing washer (1.1m for 5 days)	N/A	N/A	IECEX CML 20.0038X GB/CML/ExTR20.0044/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	------	---	-----	-----	---	--	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

3	CMP	737	Adaptor & Reducer; Type of Protection: Flameproof Ex "d", Increased Safety Ex "e" and Dust Protection by enclosure Ex "t"; Marking (Metallic Version): Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex ta IIIC Da; Marking (Non-metallic Version): Ex eb IIC Gb, Ex ta IIIC Da; (NOTE: Equipment marked with mining code are not available in aluminium)	N/A	N/A	IECEx CML 18.0177X GB/CML/ExTR18.0299/00 GB/CML/ExTR21.0102/00 GB/CML/ExTR23.0056/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	---	-----	-----	---	--	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

4	CMP	797	Adaptor & Reducer; Type of Protection: Flameproof Ex "d", Increased Safety Ex "e" and Dust Protection by enclosure Ex "t"; Marking (Metallic Version): Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex ta IIIC Da; Marking (Non-metallic Version): Ex eb IIC Gb, Ex ta IIIC Da; (NOTE: Equipment marked with mining code are not available in aluminium)	N/A	N/A	IECEx CML 18.0177X GB/CML/ExTR18.0299/00 GB/CML/ExTR21.0102/00 GB/CML/ExTR23.0056/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	---	-----	-----	---	--	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

5	CMP	747	Stopping Plug; Type of Protection: Flameproof Ex "d", Increased Safety Ex "e" and Dust Protection by enclosure Ex "t"; Marking (Metallic Version): Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex ta IIIC Da; Marking (Non- metallic Version): Ex eb IIC Gb, Ex ta IIIC Da; (NOTE: Equipment marked with mining code are not available in aluminium)	N/A	N/A	IECEx CML 18.0177X GB/CML/ExTR18.0299/00 GB/CML/ExTR21.0102/00 GB/CML/ExTR23.0056/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	--	-----	-----	---	--	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

6	CMP	757	Stopping Plug; Type of Protection: Flameproof Ex "d", Increased Safety Ex "e" and Dust Protection by enclosure Ex "t"; Marking (Metallic Version): Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex ta IIIC Da; Marking (Non- metallic Version): Ex eb IIC Gb, Ex ta IIIC Da; (NOTE: Equipment marked with mining code are not available in aluminium)	N/A	N/A	IECEx CML 18.0177X GB/CML/ExTR18.0299/00 GB/CML/ExTR21.0102/00 GB/CML/ExTR23.0056/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	--	-----	-----	---	--	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

7	CMP	767	Stopping Plug; Type of Protection: Flameproof Ex "d", Increased Safety Ex "e" and Dust Protection by enclosure Ex "t"; Marking (Metallic Version): Ex db I Mb / Ex eb I Mb, Ex db IIC Gb / Ex eb IIC Gb, Ex ta IIIC Da; Marking (Non- metallic Version): Ex eb IIC Gb, Ex ta IIIC Da; (NOTE: Equipment marked with mining code are not available in aluminium)	N/A	N/A	IECEX CML 18.0177X GB/CML/ExTR18.0299/00 GB/CML/ExTR21.0102/00 GB/CML/ExTR23.0056/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	--	-----	-----	---	--	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

8	CMP	777	Insulated Adaptor; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da	N/A	N/A	IECEX CML 18.0185U GB/CML/ExTR19.0052/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	---	-----	-----	---	--	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

9	CMP	780	Union; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb I Mb*, Ex db I Mb*, Ex eb IIC Gb, Ex db IIC Gb, Ex ta IIIC Da; Ta: -60°C to 85°C/-60°C to 200°C (See description for details); *Aluminium alloy is not acceptable for Group I applications	N/A	N/A	IECEX CML 18.0190X GB/CML/ExTR19.0038/00 GB/CML/ExTR19.0239/00 GB/CML/ExTR20.0063/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----	--	-----	-----	---	--	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

10	CMP	PX780	Union; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb I Mb*, Ex db I Mb*, Ex eb IIC Gb, Ex db IIC Gb, Ex ta IIIC Da; Ta: -60°C to 85°C/-60°C to 200°C (See description for details); *Aluminium alloy is not acceptable for Group I applications	N/A	N/A	IECEX CML 18.0190X GB/CML/ExTR19.0038/00 GB/CML/ExTR19.0239/00 GB/CML/ExTR20.0063/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
----	-----	-------	--	-----	-----	---	--	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

11	CMP	781D	Breather/Drain Plug; Type of Protection: Flameproof "db", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex ta IIIC Da	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0187U GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-31	United Kingdom
12	CMP	781E	Breather/Drain Plug; Type of Protection: Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0187U GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
13	CMP	783	(Y) and (T) shaped dual entry Adaptor; Type of Protection: Flameproof "db", Increased safety "eb", Dust Enclosure	N/A	N/A	IECEX CML 18.0171U GB/CML/ExTR21.0123/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S	United Kingdom

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			"ta"; Marking: Ex db I Mb and/or Ex eb I Mb and/or Ex db IIC Gb and/or Ex eb IIC Gb and/or Ex ta IIIC Da; Service temperature = -60°C to +200°C; Note: The Adaptor may alternatively be marked with a single concept of protection or any combination thereof as detailed above. The 'EPL' codes may be omitted from the marking string.				IEC 60079-31	
14	CMP	793	(Y) and (T)	N/A	N/A	IECEX CML 18.0171U	UAE.S	United

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

		shaped dual entry Adaptor; Type of Protection: Flameproof "db", Increased safety "eb", Dust Enclosure "ta"; Marking: Ex db I Mb and/or Ex eb I Mb and/or Ex db IIC Gb and/or Ex eb IIC Gb and/or Ex ta IIIC Da; Service temperature = -60°C to +200°C; Note: The Adaptor may alternatively be marked with a single concept of protection or any combination		GB/CML/ExTR21.0123/00 GB/CML/QAR19.0001/06	IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	Kingdom
--	--	--	--	---	---	---------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			thereof as detailed above. The 'EPL' codes may be omitted from the marking string.				
--	--	--	--	--	--	--	--

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

15	CMP	784	Union; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb I Mb*, Ex db I Mb*, Ex eb IIC Gb, Ex db IIC Gb, Ex tx IIIC Da; Ta: -60°C to 85°C/-60°C to +200°C (See description for details); *Aluminium alloy is not acceptable for Group I applications	N/A	N/A	GB/CML/ExTR19.0038/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0186U GB/CML/ExTR20.0066/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	---	-----	-----	---	--	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

16	CMP	789	Union; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb I Mb*, Ex db I Mb*, Ex eb IIC Gb, Ex db IIC Gb, Ex tx IIIC Da; Ta: -60°C to 85°C/-60°C to +200°C (See description for details); *Aluminium alloy is not acceptable for Group I applications	N/A	N/A	GB/CML/ExTR19.0038/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0186U GB/CML/ExTR20.0066/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	---	-----	-----	---	--	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

17	CMP	PX784	Union; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb I Mb*, Ex db I Mb*, Ex eb IIC Gb, Ex db IIC Gb, Ex tx IIIC Da; Ta: -60°C to 85°C/-60°C to +200°C (See description for details); *Aluminium alloy is not acceptable for Group I applications	N/A	N/A	GB/CML/ExTR19.0038/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0186U GB/CML/ExTR20.0066/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
----	-----	-------	---	-----	-----	---	--	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

18	CMP	PX789	Union; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb I Mb*, Ex db I Mb*, Ex eb IIC Gb, Ex db IIC Gb, Ex tx IIIC Da; Ta: -60°C to 85°C/-60°C to +200°C (See description for details); *Aluminium alloy is not acceptable for Group I applications	N/A	N/A	GB/CML/ExTR19.0038/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0186U GB/CML/ExTR20.0066/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
----	-----	-------	---	-----	-----	---	--	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

19	CMP	787	Right-Angled Adaptor; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0176U GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	--	-----	-----	---	--	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

20	CMP	A2e100	Cable Gland; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb I Mb, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

21	CMP	RA2e100	Cable Gland; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb I Mb, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	---------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

22	CMP	A2e100HCX	Cable Gland; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb I Mb, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

23	CMP	RA2e100HC	Cable Gland; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb I Mb, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

24	CMP	A2e100/M	Cable Gland; Type of Protection: Increased Safety "eb"; Marking: Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7	United Kingdom
25	CMP	RA2e100/M	Cable Gland; Type of Protection: Increased Safety "eb"; Marking: Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7	United Kingdom

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

26	CMP	A2e100HC/M	Cable Gland; Type of Protection: Increased Safety "eb"; Marking: Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7	United Kingdom
27	CMP	Ra2e100HC/M	Cable Gland; Type of Protection: Increased Safety "eb"; Marking: Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	IECEX CML 18.0174 GB/CML/ExTR18.0295/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7	United Kingdom

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

28	CMP	A2F	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0179X GB/CML/ExTR20.0100/00 GB/CML/ExTR23.0266/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

29	CMP	A2E	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0179X GB/CML/ExTR20.0100/00 GB/CML/ExTR23.0266/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

30	CMP	A2FRC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0179X GB/CML/ExTR20.0100/00 GB/CML/ExTR23.0266/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

31	CMP	A2F-FC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0179X GB/CML/ExTR20.0100/00 GB/CML/ExTR23.0266/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

32	CMP	A2F-HC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0179X GB/CML/ExTR20.0100/00 GB/CML/ExTR23.0266/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

33	CMP	A2F-FF	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0179X GB/CML/ExTR20.0100/00 GB/CML/ExTR23.0266/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

34	CMP	A2E-FF	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0179X GB/CML/ExTR20.0100/00 GB/CML/ExTR23.0266/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

35	CMP	A2F100	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb*, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

36	CMP	RA2F100	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb*, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	---------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

37	CMP	A2F100HC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb*, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	----------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

38	CMP	RA2F100HC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb*, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

39	CMP	RA2100HC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb*, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	----------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

40	CMP	A2F100/M	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb"; Marking: Ex db I Mb, Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7	United Kingdom
41	CMP	RA2F100/M	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb"; Marking: Ex db I Mb, Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7	United Kingdom

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

42	CMP	A2F100HC/M	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb"; Marking: Ex db I Mb, Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7	United Kingdom
43	CMP	RA2F100HC/M	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb"; Marking: Ex db I Mb, Ex eb I Mb; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7	United Kingdom

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

44	CMP	D3CDS	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb*, Ex eb IIC Gb*, Ex nR IIC Gc*, Ex ta IIIC Da*; IP66 IP67 IP68 (30m for 12 hours); Ts: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0239/00 GB/CML/ExTR18.0295/00 IECEX CML 18.0172 GB/CML/ExTR20.0010/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

45	CMP	A2FHT	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +180°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-------	--	-----	-----	---	---	-------------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

46	CMP	RA2FHT	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +180°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	---	---	-------------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

47	CMP	A2FHTHC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +180°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	---------	--	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

48	CMP	RA2FHTHC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +180°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	----------	--	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

49	CMP	A2F	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +130°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	--	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

50	CMP	RA2F	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +130°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	--	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

51	CMP	A2FHC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +130°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-------	--	-----	-----	---	---	-------------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي كسط أو تغيير في هذه الشهادة يلغونها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

52	CMP	RA2FHC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; IP66 IP67 IP68 (30m for 12 hours); Ts= -60°C to +130°C	N/A	N/A	GB/CML/ExTR18.0295/00 IECEX CML 18.0173X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	--	-----	-----	---	---	-------------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

53	CMP	C**	Cable Gland; Type of Protection: Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex nR IIC Gc (not applicable to CXe and CWe), Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0180X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	---	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

54	CMP	E**	Cable Gland; Type of Protection: Flameproof, Increased Safety, Type of Protection "n", Dust; Marking: Ex eb I Mb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex db IIC Gb, Ex nR IIC Gc; Ta = -60°C to +130°C*; Ta = -20°C to +200°C**, * When fitted with the standard seal; ** When fitted with the high temperature seal	N/A	N/A	IECEX CML 18.0181X GB/CML/ExTR18.0255/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	-----	--	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

55	CMP	PX**	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Protection by Enclosure "ta", Non- Sparking "nR"; Marking: Ex eb I Mb*, Ex db I Mb*, Ex eb IIC Gb, Ex db IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; *Aluminium alloy is not acceptable for Group I applications; -60°C to +85°C	N/A	N/A	GB/CML/ExTR19.0038/00 IECEX CML 18.0182X GB/CML/ExTR20.0196/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	--	-----	-----	--	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

56	CMP	SS2K**	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 GB/CML/ExTR19.0239/00 IECEX CML 18.0178X GB/CML/ExTR20.0060/00 GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	--------	---	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لخطم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

57	CMP	T3**	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0183X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	--	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

58	CMP	TE**	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Equipment by type of protection "nR", Dust Ignition "ta"; Marking: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da; Ta= -60°C to +130°C (standard seal) / -20°C to +200°C (high temperature seal)	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0183X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	--	-----	-----	---	---	-------------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

59	CMP	TC	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0191X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
60	CMP	TCCG	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0191X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

61	CMP	TMCX	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da; Ta: -60°C to +85°C (based upon sealing compound)	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0184X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
62	CMP	TMC	Cable Gland; Type of Protection: Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da; Ta: -60°C to +130°C	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0184X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

63	CMP	TMC2	Cable Gland; Type of Protection: Increased Safety "eb", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da; IP66	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0192X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
64	CMP	TMC2X	Cable Gland; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da; Ta= -60°C to +85°C	N/A	N/A	GB/CML/ExTR19.0052/00 IECEX CML 18.0193X GB/CML/QAR19.0001/06	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not
require stamp and signature. Certificate will be
invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي
كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

65	CMP	TSMe	Cable Gland and Plug; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; -60°C ≤ Ta ≤ +105°C; IP66 IP67 IP68 (30 m for 16 hours); IP69 IP69K	N/A	N/A	GB/CML/ExTR19.0239/00 IECEX CML 19.0062X GB/CML/ExTR19.0084/00 GB/CML/ExTR19.0236/00 GB/CML/ExTR20.0086/00 GB/CML/QAR19.0001/06 GB/CML/ExTR23.0104/00	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	---	-----	-----	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة

Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

66	CMP	TSPe	Cable Gland and Plug; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; -60°C ≤ Ta ≤ +95°C; IP66 IP67 IP68 (30 m for 16 hours); IP69 IP69K	N/A	N/A	GB/CML/ExTR19.0239/00 IECEX CML 19.0062X GB/CML/ExTR19.0084/00 GB/CML/ExTR19.0236/00 GB/CML/ExTR20.0086/00 GB/CML/QAR19.0001/06 GB/CML/ExTR23.0104/00	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	--	-----	-----	---	---	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

67	CMP	TSPi	Cable Gland and Plug; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; -60°C ≤ Ta ≤ +95°C; IP66 IP67 IP68 (30 m for 16 hours); IP69 IP69K	N/A	N/A	GB/CML/ExTR19.0239/00 IECEX CML 19.0062X GB/CML/ExTR19.0084/00 GB/CML/ExTR19.0236/00 GB/CML/ExTR20.0086/00 GB/CML/QAR19.0001/06 GB/CML/ExTR23.0104/00	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	--	-----	-----	---	---	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

68	CMP	TSXe	Cable Gland and Plug; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; -60°C ≤ Ta ≤ +105°C; IP66 IP67 IP68 (30 m for 16 hours); IP69 IP69K	N/A	N/A	GB/CML/ExTR19.0239/00 IECEX CML 19.0062X GB/CML/ExTR19.0084/00 GB/CML/ExTR19.0236/00 GB/CML/ExTR20.0086/00 GB/CML/QAR19.0001/06 GB/CML/ExTR23.0104/00	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
----	-----	------	---	-----	-----	---	---	----------------

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification

هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

69	CMP	TSZe	Cable Gland and Plug; Type of Protection: Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex eb IIC Gb, Ex ta IIIC Da, Ex nR IIC Gc; -60°C ≤ Ta ≤ +105°C; IP66 IP67 IP68 (30 m for 16 hours); IP69 IP69K	N/A	N/A	GB/CML/ExTR19.0239/00 IECEX CML 19.0062X GB/CML/ExTR19.0084/00 GB/CML/ExTR19.0236/00 GB/CML/ExTR20.0086/00 GB/CML/QAR19.0001/06 GB/CML/ExTR23.0104/00	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	United Kingdom
Nothing Follows								

intertek
Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



This is an electronic certificate and does not require stamp and signature. Certificate will be invalid in case of any modification



هذه الشهادة صدرت إلكترونياً ولا تحتاج لختم أو توقيع، أي كشط أو تغيير في هذه الشهادة يلغيها.