




EU Type Examination Certificate CML 18ATEX1324X Issue 0


- 1 Component intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Component **Cable Gland Types E****
- 3 Manufacturer **CMP Products Ltd**
- 4 Address Unit 36 Nelson Way,
Nelson Park East,
Cramlington,
Northumberland,
NE23 1WH, UK
- 5 The component is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V. , Chamber of Commerce No 6738671, Hoogoorddreef 15, Amsterdam, 1101 BA, The Netherlands, Notified Body Number 2776, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018 EN 60079-1:2014 EN 60079-7:2015+A11:2018
EN 60079-31:2014


- 10 The equipment shall be marked with the following:



Ex eb I Mb
Ex db I Mb



Ex eb IIC Gb
Ex db IIC Gb



Ex ta IIIC Da

Ta = -60°C to +130°C*

Ta = -20°C to +200°C**

* When fitted with the standard seal

** When fitted with the high temperature seal

A Snowdon



CML 18ATEX1324X
Issue 0

11 Description

The E** series Type ranges of cable glands consist of a male-threaded front entry component containing an elastomeric sealing ring and a Nylon 6 skid washer which effect flameproof sealing onto the cable inner sheath and is intended to screw into an entry point of its associated enclosure in accordance with relevant codes of practice. The flameproof seal is actuated by an adjoining coupling component. The coupling component is attached to a main body. Their mating thread may be fitted with an optional 'O' ring seal to provide increased ingress protection. Clamping of the armoured or braided cable is effected by a combination of the coupling component, main body and the different optional armour cone and armour sleeve combinations being fastened together. An outer seal nut, containing an elastomeric sealing ring and a Nylon 6 ferrule, threads onto the main body and effects environmental sealing onto the cable outer sheath.

Design options:-

- The option for metric threaded cable entry spigots of all cable gland model series to be manufactured with a thread pitch between 0.7mm and 2.0mm.
- The front entry component may be manufactured with a profiled groove to captivate an 'O' ring seal which locates on the mating face with the associated enclosure. This option having the gland type designation prefixed with the letter R, e.g. 25RE1FW.
- Materials of manufacture:
 - Brass to EN12168:1998 Grade CuZn39Pb (CW614N)
 - Mild steel to BS EN 10088-3:2005 Grade 220M07Pb
 - Stainless steel to BS EN 10088-3:2005 Grade 316S11, 316S13, 316S31 or 316S33
 - Aluminium alloy not inferior to grade 6082 to EN755,1-3:1996 or LM25 to BS EN 1676:2010 (Not Group I)
- Alternative entry component thread forms:
 - Metric ISO 965-1, ISO965-3 medium fit (6g) for external threads
 - ET(Conduit) BS 31:1940 (1979), Table A
 - PG DIN 40430:1971
 - BSPP BS 2779:1973 class A full form for external threads
 - BSPT BS 21:1985 standard threads only as clause 5.4, gauging to clause 5.2 system A
 - ISO ISO 7/1:1982, gauging to ISO 7/2 clause 6.3 for external threads
 - NPT ANSI/ASME B1.20.1-1983 gauging to clause 8.1 for external threads
 - NPSM ANSI/ASME B1.20.1-1983 gauging to clause 9 for external threads
- The option to manufacture glands with entry threads that are one size up from the nominal quoted gland size.
- The use of alternative armour clamping components specified by the cable gland type designation. The various arrangements vary the cable gland suitability for differing armour or braided type cables.
- The use of a component having an alternative profile allowing an integral earthing facility. The type designation identifying the cable gland being fitted with this option.
- The use of metallic continuity diaphragm component specified by the cable gland type designation for use when terminating lead sheathed cables.
- The use of an earthing device component specified by the cable gland type designation for use with variable speed drive (VSD) / variable frequency drive (VFD) cables.
- Alternative material of manufacture of the ferrule to be the same as the gland material.
- The use of seals suitable for flat form cables
- The use of an O ring seal between the body and the entry item to provide a deluge seal.



**CML 18ATEX1324X
Issue 0**

- Alternative outer seal arrangement to allow the glands to be fitted to flexible conduit.
- The option to fit a blanking disc between the outer seal and the main body to maintain a minimum IP66 rating. The disc is to be marked 'Ex e only' to indicate that the gland is not suitable for Ex d applications when the disc is fitted.

The gland and seal sizes are determined by the entry thread and cable range take sizes:

Gland size	Entry thread	Entry thread 'B' version	Inner seal sheath range Ø (mm)		SWA (mm)		SWA, STA, strip armour, pliable wire armour* & wire braid (mm)		Outer seal sheath range Ø (mm)	
			Min	Max	Min	Max	Min	Max	Min	Max
16	M16 x 1.5	-	3.1	8.6	0.8	1.25	0	0.8	6.1	13.2
20s/16	M20 x 1.5	M25 x 1.5	3.1	8.6	0.8	1.25	0	0.8	6.1	13.2
20s16/20s	M20 x 1.5	M25 x 1.5	3.1	8.6	0.8	1.25	0	0.8	9.5	15.9
20s	M20 x 1.5	M25 x 1.5	6.1	11.6	0.8	1.25	0	0.8	9.5	15.9
20s/20	M20 x 1.5	M25 x 1.5	6.1	11.6	0.8	1.25	0	0.8	12.5	20.9
20	M20 x 1.5	M25 x 1.5	6.5	13.9	0.8	1.25	0	0.8	12.5	20.9
20/25s	M20 x 1.5	M25 x 1.5	6.5	13.9	1.25	1.6	0	1.1	14.0	22.0
20/25	M20 x 1.5	M25 x 1.5	6.5	13.9	1.25	1.6	0	1.1	18.2	26.2
25s	M25 x 1.5	M32 x 1.5	11.1	19.9	1.25	1.6	0	1.1	14.0	22.0
25	M25 x 1.5	M32 x 1.5	11.1	19.9	1.25	1.6	0	1.1	18.2	26.2
25/32	M25 x 1.5	M32 x 1.5	11.1	19.9	1.6	2.0	0	1.2	23.7	33.9
32	M32 x 1.5	M40 x 1.5	17.0	26.2	1.6	2.0	0	1.2	23.7	33.9
32/40	M32 x 1.5	M40 x 1.5	17.0	26.2	1.6	2.0	0	1.2	27.9	40.4
40	M40 x 1.5	M50 x 1.5	22.0	32.1	1.6	2.0	0	1.2	27.9	40.4
40/50s	M40 x 1.5	M50 x 1.5	22.0	32.1	2.0	2.5	0	1.5	35.2	46.7
50s	M50 x 1.5	M63 x 1.5	29.5	38.1	2.0	2.5	0	1.5	35.2	46.7
50s/50	M50 x 1.5	M63 x 1.5	29.5	38.1	2.0	2.5	0	1.5	40.4	53.1
50	M50 x 1.5	M63 x 1.5	35.6	44.0	2.0	2.5	0	1.5	40.4	53.1
50/63s	M50 x 1.5	M63 x 1.5	35.6	44.0	2.0	2.5	0	1.5	45.6	59.4
63s	M63 x 1.5	M75 x 1.5	40.1	49.9	2.0	2.5	0	1.5	45.6	59.4
63s/63	M63 x 1.5	M75 x 1.5	40.1	49.9	2.0	2.5	0	1.5	54.6	65.9
63	M63 x 1.5	M75 x 1.5	47.2	55.9	2.0	2.5	0	1.5	54.6	65.9
63/75s	M63 x 1.5	M75 x 1.5	47.2	55.9	2.0	2.5	0	1.5	59.0	72.1
75s	M75 x 1.5	M90 x 2.0	52.8	61.9	2.0	2.5	0	1.5	59.0	72.1
75s/75	M75 x 1.5	M90 x 2.0	52.8	61.9	2.5	3.0	0	1.5	66.7	78.5
75	M75 x 1.5	M90 x 2.0	59.1	67.9	2.5	3.0	0	1.5	66.7	78.5
75/90	M75 x 1.5	M90 x 2.0	59.1	67.9	3.0	3.5	0	1.6	76.2	90.4
90	M90 x 2.0	M100 x 2.0	66.6	79.9	3.0	3.5	0	1.6	76.2	90.4
90/100	M90 x 2.0	M100 x 2.0	66.6	79.9	3.15	4.0	0	1.6	86.1	101.5
100	M100 x 2.0	M115 x 2.0	76.0	90.9	3.15	4.0	0	1.6	86.1	101.5
100/115	M100 x 2.0	M115 x 2.0	76.0	90.9	3.15	4.0	0	1.6	101.5	110.3
115	M115 x 2.0	M130 x 2.0	86.0	97.9	3.15	4.0	0	1.6	101.5	110.3
115/130	M115 x 2.0	M130 x 2.0	86.0	97.9	3.15	4.0	0	1.6	110.2	123.3
130	M130 x 2.0	N / A	97.0	114.9	3.15	4.0	0	1.6	110.2	123.3



CML 18ATEX1324X
Issue 0

13 Conditions of manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- 13.1 Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.

14 Specific Condition of Use (Special Conditions)

The following conditions relate to safe installation and/or use of the equipment.

- 14.1 The E**-Type cable glands shall not be used to terminate on braided cables in group I applications.
- 14.2 The glands when used for terminating braided cables are only suitable for fixed installations. Cables must be effectively clamped to prevent pulling or twisting.
- 14.3 When the cable glands are supplied with an entry thread that is one size up from the nominal gland size, designated with the letter 'B' after the gland size, e.g. 32B****, they shall not be used with any adaptor device.
- 14.4 When assembled for fitting to flexible conduit, the conduit shall be effectively clamped to prevent twisting and pulling.



Certificate Annex

Certificate Number CML 18ATEX1324X
Equipment Cable Gland Types E**
Manufacturer CMP Products Ltd

The following documents describe the equipment or component defined in this certificate:

Issue 0

Drawing No	Sheets	Rev	Approved date	Title
GA355	1 of 1	01	11 Dec 2018	E Type Series General Arrangement
SCH0321	1 of 1	00	11 Dec 2018	Inner seal details
SCH0322	1 of 1	00	11 Dec 2018	Outer seal details
SCH0323	1 of 1	00	11 Dec 2018	Armour clamp details