



中国国家强制性产品认证证书



证书编号: 2020322313003177

认证委托人名称: CMP PRODUCTS LTD
 认证委托人地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产者名称: CMP PRODUCTS LTD
 生产者地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产企业名称: CMP PRODUCTS LTD
 生产企业地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

产品名称: 转接头
 系列、规格、型号: 737/797/787/780/PX780/784/PX784/789/PX789
 标准: GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020 年 11 月 6 日 有效期至: 2025 年 11 月 5 日

首次发证日期: 2020 年 11 月 6 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313003177

APPLICANT: **CMP PRODUCTS LTD**
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

MANUFACTURER: **CMP PRODUCTS LTD**
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

FACTORY: **CMP PRODUCTS LTD**
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

PRODUCTNAME: Reducers/Adaptors/Unions

SERIES,SPECIFICATION,MODEL: 737/797/787/780/PX780/784/PX784/789/PX789

STANDARDS: GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: November 6, 2020 **Valid until:** November 5, 2025

Date of original certification: November 6, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL: 
 Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844



中国国家强制性产品认证证书



证书编号：2020322313003177

附件

产品名称：转接头

型号规格：737/797/787/780/PX780/784/PX784/789/PX789

1. 737/797 型（金属材质）螺纹规格如下（还有其他组合形式）：

转接头		变径管	
内螺纹形式	外螺纹形式	内螺纹形式	外螺纹形式
M20×1.5*	M16×1.5*	M16×1.5	M20×1.5
M20×1.5	M20×1.5	M20×1.5	M25×1.5
M32×1.5	M25×1.5	M25×1.5	M32×1.5
M40×1.5	M32×1.5	M32×1.5	M40×1.5
M50×1.5	M40×1.5	M40×1.5	M50×1.5
M63×1.5	M50×1.5	M50×1.5	M63×1.5
M75×1.5	M63×1.5	M63×1.5	M75×1.5
M90×2.0	M75×2.0	M75×1.5	M90×2.0
M100×2.0*	M90×2.0*	M90×2.0*	M100×2.0*

737 型有金属和非金属两种规格，*为金属规格。

2. 787 型螺纹规格如下：

M20×1.5~M100×2.0

3. 780, PX780, 784, PX784, 789, PX789 型螺纹规格如下：

M16~M100

除以上所列螺纹规格外，还可选满足 ANSI/ASME B1.20.1-1983 第 8.1 条外螺纹要求的 NPT 螺纹。

防爆标志：Ex d IIC Gb / Ex e IIC Gb; Ex tD A20 IP6X。

电气参数：/

批 准：



上海仪器仪表自控系统检验测试所有限公司