

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	CMP Products Limited
Address	Glasshouse Street, St. Peters, Newcastle-Upon - Tyne, NE6 1BS, United Kingdom
Type	Cable Glands and Approved Accessories
Description	Cable glands and Stopping Plugs for non-hazardous areas in Marine, offshore and Industrial use
Trade Name	CMP
Application	Cable glands for the installation in ordinary, industrial, and hazardous locations
Specified Standard	See Appendix for Details
Ratings	See Appendix for Details
Other Conditions	The equipment should not be used for the protection of cables passing through watertight, fire insulated or gas tight bulkheads or decks separating dangerous zones or spaces from non-dangerous zones or spaces. 717 Series The installer shall refer to the manufacturer's instructions for the action



Matt Higgins

Senior Electrical Specialist to Lloyd's Register
EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Type Approval Certificate

necessary regarding the electrostatic risk associated with the non-metallic stopping plug.

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 01/00171(E3)

The Design Appraisal Document LR22320255TA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Appendix

TYPE	STANDARD	APPLICATION
BW	BS 6121:1989	Indoor use
BWL	BS 6121:1989	Indoor use
E2X	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
E1U	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
E2U	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
A2RC	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
A2	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
CW	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
EIW	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
CX	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
EIX	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
E2W	BS 6121:1989, EN 62444:2013, IEC 62444:2010	Indoor/outdoor use
C2K-GP	BS 6121:1989	Jacketed cable
SS2KGP	BS 6121:1989, EN 62444:2013, IEC 62444:2010	
SS2KGP-PB	BS 6121:1989, EN 62444:2013, IEC 62444:2010	
717 Series Stopping Plugs	IEC 62444:2010; BS EN 62444 2013	

Non-Armoured					
Gland Range	According to material and cable	According to mechanical properties	According to electrical properties	According to resistance to external	According to sealing system
TSX	Metallic cable gland for all types of braided and screened cables	Impact category: 6 Anchorage type: A (for single orifice seal only)	Equipotential bonding to metallic layer(s) of cable Cable glands with connection to protective earth, Category A	IP66/67/68/69/69K Temp range: -60°C to +105°C	Single orifice seal or multi-orifice seal*
TSM and TSZ	Metallic cable gland for all types of braided and screened cables	Impact category: 6 Anchorage type: A (for single orifice seal only)	TSM Equipotential bonding to enclosure TSZ Equipotential bonding to metallic layer(s) of cable Cable glands with connection to protective earth, Category A	IP66/67/68/69/69K Temp range: -60°C to +105°C	Single orifice seal or multi-orifice seal*

TSP and TSPV0	Non-Metallic for unarmoured cable	Impact category.			No requirement	IP66/67/68/69/69K Temp range: TSP -60°C to +100°C TSPV0 -40°C to +100°C	Single orifice seal or multi-orifice seal*
		Size	TSP	TSPV0			
		M12	4	2			
		M16	4	3			
		M20	6	3			
		M25	6	4			
		M32	6	4			
		M40	6	4			
		M50	6	5			
		M63	6	5			
Anchorage type: A (for single orifice seal only)							

* The multi-orifice seal is only rated to IP66,67,68

Type	717 (including suffix 'e', 'E' variants)
Design Specification	IEC 62444: 2010, EN 62444:2013
Classification	Ex eb IIC Gb / Ex ta IIIC Da
Compliance Code	IEC 60079-0:2017 (EN:2018), IEC 60079-7:2017 (EN:2015+A1:2018), IEC 60079-31: 2013 (EN:2014)
Certification	CML 20ATEX3054X CML 21UKEX3237X IECEX CML 20.0038X
Continuous operating temperature range	-60 °C to +95 °C
Ingress protection	IP66, IP67, IP68*, IP69, IP69K * with sealing washer: 30m for 16 hours * without sealing washer: 1.1m for 5 days